

# Preliminary Assessment Report Project 6413987, 2550 34TH AVE W

Assessment Completed: 5/12/2014

**Project Description:** Install (1) double portable classroom (28x64) and entry ramp on the Catharine Blaine K-8

School site, Occupy per plan.

**Primary Applicant: Stuart Stovin** 

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

## **Next Steps**

- 1. Review the requirements in this report and contact the staff members listed below with questions.
- 2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See <a href="SDOT Client Assistance Memo 2213">SDOT Client Assistance Memo 2213</a> for quidance about the 60% complete approval process.
- 3. Schedule an appointment for permit application intake with DPD. Please bring a copy of this report to your intake appointment.

## **Questions About This Report**

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### **DPD Drainage Requirements**

Ede M Courtenay, (206) 733-9679, Ede.Courtenay@seattle.gov

#### **DPD Land Use Requirements**

Arthur J Pederson, (206) 684-0638, <a href="mailto:art.pederson@seattle.gov">art.pederson@seattle.gov</a>

## **DPD Preapplication Site Visit Requirements**

Douglas Thresher, (206) 233-3875, <a href="Douglas.Thresher@seattle.gov">Douglas.Thresher@seattle.gov</a>

# **Seattle City Light Requirements**

Ray Ramos, (206) 615-1193, <a href="mailto:ray.ramos@seattle.gov">ray.ramos@seattle.gov</a>

#### **Seattle Department of Transportation Requirements**

Yohannes Minas, (206) 733-9044, <a href="mailto:yohannes.minas@seattle.gov">yohannes.minas@seattle.gov</a>

#### **Seattle Public Utilities Requirements**

Lan Chau

#### **Other Resources**

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: DPD and SDOT.
- Detailed zoning information.
- Visit our <u>permit type pages</u> for step-by-step instructions and forms for preparing your application and plans for review.

# Requirements

# **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

## **Existing Public Drainage Infrastructure**

Sanitary sewer main location: 32nd Ave W

Sanitary sewer main size: 12" clay Storm drainage main location: Onsite Storm drainage main size: 42" RCP

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Public storm drain system.

A build-over agreement will be required with SPU for this project. See <u>Tip 507</u>, <u>Side Sewer Permits for Build-Over Agreements</u>, for instructions on applying for a build-over review.

New easements or relinquishing existing easements requires City Council action prior to building permit approval, and may take up to 18 months. Revisions to existing easements are sometimes required for Construction Permits.

## **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed Construction Stormwater Control and Soil Amendment Standard Plan is required.

#### **Water Quality**

No requirements

## **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge (<u>DPD DR 4-2011</u>) is located at the following: Public storm drain system.

# **DPD Land Use Code Requirements**

#### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (http://www.seattle.gov/transportation/rowimanual/manual/). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

#### 34TH AVE W

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

#### 32ND AVE W

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

## **W SMITH ST**

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

# **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

Street conditions are not included as the proposed project is deep within the site on flat asphalt with existing catch basins.

## **ECA Mapping Unit and Type**

Non-ECA

#### **Earth Disturbance**

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

## **Potential Impacts to Seattle Parks Property**

Park within 100 LF

#### **Tree Protection**

Existing trees appear to be shown accurately on the site plan

## **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (<u>DR 16-2009</u>, Volume 2).

## Show the following on the **Construction Stormwater Control and Soil Amendment Standard Plan**:

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at

http://web1.seattle.gov/DPD/InspectionRequest/default.aspx.

# **Seattle City Light Requirements**

## **Notes to Applicant**

Power for the new portable must come from the existing electrical service to the site per SCL's "one site-one service" rule. For clarification and advice, please contact your Electrical Service Representative, Tim Harris at 206-615-0115, or tim.harris@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

# **SDOT Requirements**

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

# **SPU Requirements**

Based on the information provided at this time, it appears that no street improvements are required. Be advised that it is the applicant's responsibility to seek guidance from SPU should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SPU at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos 004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, <u>Liz.Kain@seatte.gov</u>.

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark of if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, <a href="Michale.Crooks@seattle.gov">Michale.Crooks@seattle.gov</a>, or visit the <a href="Licensing and Tax Administration Division website.">Licensing and Tax Administration Division website.</a>